



**A REGULATED UTILITY**

**Mail:** 119 S. Heber St. Beckley, WV 25801  
 PO Box 2400 Beckley, WV 25802-2400  
**Phone:** 304.255.5121  
**Fax:** 304.255.5134  
**Web:** [beckleywater.com](http://beckleywater.com)

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

AVAILABILITY OF MONITORING DATA FOR UNREGULATED CONTAMINANTS FOR  
**BECKLEY WATER COMPANY - PWSID #WV3304104**

*Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by the USEPA. The purpose of monitoring for these contaminants is to help the EPA decide whether the contaminants should have a standard. Following results are for the sampling period ending 2020.*

**Unregulated Contaminant Monitoring Rule 4 (UCMR4)**

**Am1 Metals, Pesticides, Alcohols, and SVOCs Sampling**

Entry Point After Treatment (Finished Water)  
 Glade Creek Treatment Plant

Contaminant	1st Qtr	3rd Qtr	4th Qtr	Average
<b>Pesticides</b>				
alpha-Hexachlorocyclohexane	ND	ND	ND	ND
Chlorpyrifos	ND	ND	ND	ND
Dimethipin	ND	ND	ND	ND
Ethoprop	ND	ND	ND	ND
Oxyfluorfen	ND	ND	ND	ND
Profenofos	ND	ND	ND	ND
Tebuconazole	ND	ND	ND	ND
Total Permethrin	ND	ND	ND	ND
Tribufos	ND	ND	ND	ND
<b>SVOC</b>				
Butylated hydroxyanisole	ND	ND	ND	ND
o-Toluidine	ND	ND	ND	ND
Quinoline	ND	ND	ND	ND
<b>Alcohol</b>				
1-Butanol	ND	ND	ND	ND
2-Methoxyethanol	ND	ND	ND	ND
2-propen-1-ol	ND	ND	ND	ND
<b>Metals</b>				
Germanium	ND	ND	ND	ND
Manganese	1.1ug/L	1.6ug/L	2.7ug/L	1.8ug/L

**Am1 Metals, Pesticides, Alcohols, and SVOCs Sampling**

Entry Point After Treatment (Finished Water)  
 Sweeneysburg Treatment Plant

Contaminant	1st Qtr	2nd Qtr	3rd Qtr	Average
<b>Pesticides</b>				
alpha-Hexachlorocyclohexane	ND	ND	ND	ND
Chlorpyrifos	ND	ND	ND	ND
Dimethipin	ND	ND	ND	ND
Ethoprop	ND	ND	ND	ND
Oxyfluorfen	ND	ND	ND	ND
Profenofos	ND	ND	ND	ND
Tebuconazole	ND	ND	ND	ND
Total Permethrin	ND	ND	ND	ND
Tribufos	ND	ND	ND	ND
<b>SVOC</b>				
Butylated hydroxyanisole	ND	ND	ND	ND
o-Toluidine	ND	ND	ND	ND
Quinoline	ND	ND	ND	ND
<b>Alcohol</b>				
1-Butanol	ND	ND	ND	ND
2-Methoxyethanol	ND	ND	ND	ND
2-propen-1-ol	ND	ND	ND	ND
<b>Metals</b>				
Germanium	ND	ND	ND	ND
Manganese	ND	2.0ug/L	1.6ug/L	1.2ug/L

**Am2 Disinfection Byproducts Sampling**  
Intake (Raw Water) and Distribution System (Finished Water)  
Glade Creek Treatment Plant

Contaminant	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Average
<b>Intake</b>					
Bromide	.010 mg/L	.008 mg/L	.014 mg/L	.015 mg/L	.012mg/L
TOC	2.32 mg/L	2.77 mg/L	3.09 mg/L	2.33 mg/L	2.63 mg/L
<b>4-H Lake Road 2-J</b>					
HAA5	20.4 ug/L	28.0 ug/L	52.1 ug/L	21.5 ug/L	30.5 ug/L
HAA6Br	3.99 ug/L	4.1 ug/L	6.2 ug/L	4.8 ug/L	4.77 ug/L
HAA9	24.4ug/L	31.8 ug/L	58.3 ug/L	26.3 ug/L	35.2 ug/L
<b>E. Whitby Road Site-A</b>					
HAA5	14.2 ug/L	31.8 ug/L	33.6 ug/L	19.2 ug/L	24.7 ug/L
HAA6Br	3.07 ug/L	4.3 ug/L	4.9 ug/L	4.4 ug/L	4.17 ug/L
HAA9	17.3 ug/L	36.1 ug/L	38.5 ug/L	23.6 ug/L	28.9 ug/L
<b>Raleigh Co. PSD Office 2-K</b>					
HAA5	22.4 ug/L	27.5 ug/L	35.4 ug/L	23.3 ug/L	27.2 ug/L
HAA6Br	4.3 ug/L	3.7 ug/L	5.3 ug/L	5.2 ug/L	4.63 ug/L
HAA9	26.7 ug/L	31.2 ug/L	40.7 ug/L	28.5 ug/L	31.8 ug/L
<b>Beckley Water Co. Office 2-C</b>					
HAA5	16.9 ug/L	24.5 ug/L	37.3 ug/L	20.3 ug/L	24.8 ug/L
HAA6Br	3.8 ug/L	3.2 ug/L	5.3 ug/L	4.7 ug/L	4.25 ug/L
HAA9	20.7 ug/L	27.7 ug/L	42.6 ug/L	25.0 ug/L	29.0 ug/L
<b>System Total</b>	<b>Average</b>		<b>Range High</b>		<b>Range Low</b>
HAA5	26.8 ug/L		52.1 ug/L		14.2 ug/L
HAA6Br	4.45 ug/L		6.2 ug/L		3.07 ug/L
HAA9	31.2 ug/L		58.3 ug/L		17.3 ug/L

**Am3 Cyanotoxins Sampling**

Entry Point Before Treatment (Raw Water)  
Glade Creek Treatment Plant

Contaminant	June Week 1	June Week 3	July Week 1	July Week 3	August Week 1	August Week 3	September Week 1	September Week 3
Anatoxin-a	ND	ND	ND	ND	ND	ND	ND	ND
Cylindrospermopin	ND	ND	ND	ND	ND	ND	ND	ND
Total Microcystin	ND	ND	ND	ND	ND	ND	ND	ND

**Definitions:** ug/L=Micrograms per Liter      mg/L=Milligrams per Liter      HAA= Haloacetic Acids      ND= Not Detected

If you are interested in examining the results, please contact;  
**Louis Wooten** at 304.255.5121 or PO Box 2400, Beckley, WV 25802-2400

*Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).*